

CITY OF VINELAND

May 3, 2016

REPORT TO: THE MAYOR AND COUNCIL

**RE: Street Lighting Recommendations
May 2016**

Dear Mayor and Members of Council:

Submitted to you herewith is a request for street lighting improvements which is ready for your approval. A copy of the recommendation of the City of Vineland Electric Utility with respect to this request, along with a copy of the drawing identifying the area in question, is attached for your review.

Should you have any questions pertaining to this matter, please do not hesitate to contact this office.

Respectfully submitted,



Robert Dickenson
Assistant Business Administrator

/r/

Encls.

cc: Joseph Isabella
Jackie Muccirelli

Approved:



Mayor

4/23/16

Date

CITY OF VINELAND

STREET LIGHTING RECOMMENDATION

April 2016

REQUEST

1. W. Forest Grove Road
Drawing No. VMEU-2881

RECOMMENDATION

Upgrade six (6) existing street lights to 72W LED and two (2) existing street lights to 108W LED. Also, the installation of six (6) additional 72W LED street lights.

MEMORANDUM

April 15, 2016

TO: ROBERT E. DICKENSON, JR.
ASSISTANT BUSINESS ADMINISTRATOR

FROM: JOSEPH A. ISABELLA
DIRECTOR OF MUNICIPAL UTILITIES

SUBJECT: STREET LIGHT SURVEY



The area mentioned below has been investigated for the possibility of installing additional street lights or for the possibility of upgrading existing street lights:

Name: John T. Boyle, Jr.
Address: W. Forest Grove Road
Vineland, NJ 08360
Telephone: 856-794-4000, Ext. 4295

The following has been recommended by the Vineland Municipal Electric Utility:

Upgrade of six (6) existing street lights to 72W LED and two (2) existing street lights to 108W LED. Also, the installation of six (6) additional 72W LED street lights.


This recommendation is illustrated on the Vineland Municipal Electric Utility Drawing No. VMEU-2881 which is attached.

JAI:djb

Attachments

VINELAND MUNICIPAL UTILITIES (VMU)
VINELAND, NEW JERSEY 08360

STREET LIGHT PROPOSAL



DATE: April 14, 2016

TO: John T. Boyle, Jr.

RE: Survey at : W. FOREST GROVE RD. PROPOSED BY:

NAME: John Boyle

ADDRESS: VMU

The preceding mentioned location has been surveyed by VMU to ensure proper street lighting in conformance with standard City practice. As a result, we propose the following enhancement(s):

Proposed: Upgrade six (6) existing st. lts. to 72 W LED and two (2) existing st.lts to 108 W LED .


Install six (6) additional 72 W LED and per attached dwg.

Yours truly,

A handwritten signature in black ink that reads "J. Boyle".

Attachments: DWG.#VMEU-2881

Approved by : John T. Boyle, Jr.
Assist. General Manager
Vineland Municiple Utilities



NOTE:

- (4) 50 HPS
- (2) 100 MV
- (1) 100 SV
- (1) 70 HPS
- (1) 100 HPS


REVISIONS		BY	DATE
1			
2			
3			

STREET LIGHT REVISION	
FOREST GROVE RD BETWEEN MILL RD & DELSEA DR	
VINELAND MUNICIPAL ELECTRIC UTILITY	
VINELAND, NEW JERSEY	
ENGINEER: JTB	DRAWN: SAGAR, 4/11/2016
DRAWING # VMEU-2881	JOB #: 16-100-AT-1


SHEET 1 OF 2

UNDEVELOPED

LIGHT INDUSTRIAL



4



PLATE

PLATE

ALUMINUM

ALUMINUM

ALUMINUM

ALUMINUM

ALUMINUM

REVISIONS		
NO.	DESCRIPTION	DATE
1		
2		
3		

STREET LIGHT REVISION	
FOREST GROVE RD BETWEEN MILL RD & DELSEA DR	
VINELAND MUNICIPAL ELECTRIC UTILITY	
VINELAND, NEW JERSEY	
ENGINEER: JTB	DRAWN: SAGAR, 4/11/2016
DRAWING # VMEU-2881	JOB #: 16-100-AT-II

SHEET 2 OF 2

LIGHT INDUSTRIAL

UNDEVELOPED

