

CITY OF VINELAND
DEPARTMENTAL REQUEST FOR PUBLIC BIDDING

1. NATURE OF REQUEST: Fire Suppression System for West Unit 1

2. ENGINEER'S ESTIMATE: \$ 95,000
(If Engineer's Estimate has been prepared by anyone other than the person signing this form, please attach a copy of said Engineer's Estimate.)



3. AMOUNT BUDGETED FOR THIS REQUESTED ITEM: \$ 70,000.00

4. BUDGETED ITEM: YES NO
(If no, is it an ordinance authorized material, service or supply?)

YES NO ORDINANCE NO.: _____

(B) Please identify the page number and line item appropriation sub-account:

Budget Page No. _____ Account No. 002-0-55-90-9001-2-9022000,
E344

5. Check here if:

Federal Funds State Funds
UEZ Funds Davis Bacon Requirements

(If any of the above are checked, the project must be monitored by the department for compliance with prevailing wage rate policy and procedures.)

6. Date to be Advertised: November 28, 2017

7. Date to be Received: December 27, 2017

8. Date to be Awarded: January 30, 2018

9. Special Conditions or Instructions: _____

10. The following must be attached:

Summary of Project

Specifications

Plans (if applicable)

Bidders Mailing List (with emails of the vendor)

JLC 11/7/17

11. Specifications Prepared by: Joseph L. Colla, Principal Engineer, 4353
(NAME, TITLE AND EXTENSION NUMBER)

Jm 11/08/17
Ben Foster 11/9/17

12. Approved by: *John Lella* 11-9-17
SIGNATURE (DIRECTOR, DEPARTMENT HEAD, SUPERVISOR)

(Signature)

Send copies to:
Purchasing Department
Business Administration

Supply and Installation of Fire Suppression System

West Unit 1 Combustion Turbine

The existing fire suppression system for the West Unit 1 combustion turbine is inoperable and needs to be replaced. The system was included with the installation of the combustion 45 years ago. The city's fire insurance carrier has mandated the fire suppression system be replaced. A request for proposals that includes a specification for a gaseous fire suppression system has been prepared. The original fans and dampers connected to the combustion turbine enclosure building and control room have been replaced with new fans and dampers. The fans must shutdown and the dampers close for the enclosure to be air tight immediately prior to the discharge of the gaseous fire suppressant. The specification has been reviewed and approved by the city's fire insurance carrier.

J. L. Colla

[Signature]