#### CITY OF VINELAND

December 19, 2017

REPORT TO: THE MAYOR AND COUNCIL

RE: Street Lighting Recommendations December 2017

Dear Mayor and Members of Council:

Submitted to you herewith are requests for street lighting improvements which are ready for your approval. Copies of the recommendations of the City of Vineland Electric Utility with respect to these requests, along with copies of the drawings identifying the areas in question, are attached for your review.

Should you have any questions pertaining to this matter, please do not hesitate to contact this office.

Respectfully submitted,

Robert E. Dickenson, Jr Business Administrator

/rl Encls.

cc: John Lillie

Susan Baldosaro

Approved:

Date

### **CITY OF VINELAND**

#### STREET LIGHTING RECOMMENDATIONS

#### **DECEMBER 2017**

#### **REQUEST**

#### **RECOMMENDATIONS**

- 1. Area of Butler Avenue
  (between East Blvd & Lincoln Ave)
  Drawing No. VMEU-2851
- 2. Area of East Blvd (between Weymouth Rd and Wheat Rd)
  Drawing No. VMEU-2852
- 3. Area of Hance Bridge Road (between Panther Rd & Sherman Ave)
  Drawing No. VMEU-2853

Upgrade one (1) existing street light to 54W LED, ten (10) 74W LED (relocating five (5) street lights), and four (4) 108W LED. Install five (5) additional 74W LED street lights onto existing utility poles.

Upgrade eleven (11) existing street lights to 74W LED (relocating nine (9) street lights), and three (3) 108W LED. Install nine (9) additional 74W LED street lights onto existing utility poles.

Upgrade fifteen (15) existing street lights to 74W LED, and five (5) to 108W LED. Install three (3) additional 74W LED street lights onto existing utility poles.

#### VINELAND MUNICIPAL ELECTRIC UTILITY

VINELAND, NEW JERSEY 08360

#### STREET LIGHT REQUEST

CITY OF VINELAND BUSINESS ADMIN.

DATE:

October 4, 2017

TO:

Bob Dickenson

**Business Administrator** 

PROPOSED BY:

RE:

Survey at: Area of Butler Ave.

NAME:

John T. Boyle

between East Blvd. and Lincoln Ave.

ADDRESS:

VMU

The preceding-mentioned location has been surveyed by VMU to ensure proper street lighting in conformance with standard City practice. As a result, we propose the following enhancement(s):

PROPOSED: Upgrade one (1) existing street light to 54W LED, ten (10) 74W LED (relocating five street lights), and four (4) 108 W LED. Install five (5) additional 74W LED st. lt. onto existing utility poles.

Yours truly,

Approved by:

John T. Boyle, Jr.

Assistant General Manager Vineland Municipal Utilities

Attachments: DWG.#VMEU-2851

#### VINELAND MUNICIPAL ELECTRIC UTILITY

VINELAND, NEW JERSEY 08360

#### STREET LIGHT REQUEST



		(30
O:	Bob Dickenson	1
	D :	

October 24, 2017

T

Business Administrator

PROPOSED BY:

RE:

Survey at: Area of East Blvd.

NAME:

DATE:

John T. Boyle

between Weymouth Rd. and Wheat Rd.

ADDRESS:

VMU

The preceding-mentioned location has been surveyed by VMU to ensure proper street lighting in conformance with standard City practice. As a result, we propose the following enhancement(s):

PROPOSED: Upgrade eleven (11) existing street lights to 74W LED (relocating nine (9) street lights),
and three (3) 108W LED. Install nine (9) additional 74W LED st. lt. onto existing utility poles.
•

Yours truly,

Approved by:

John T. Boyle, Jr.

Assistant General Manager Vineland Municipal Utilities

Attachments: DWG.#VMEU-2852

## VINELAND MUNICIPAL ELECTRIC UTILITY

VINELAND, NEW JERSEY 08360

### STREET LIGHT REQUEST

RECEIVED

NOV 1 4 2017

CITY OF VINELAND BUSINESS ADMIN.

		DATE:	November 8, 2017
	(80)		
TO:	Bob Dickenson		
	Business Administrator		
			PROPOSED BY:
RE:	Survey at : Area of Hance Bridge Rd.	NAME:	John T. Boyle
	between Panther Rd. and Sherman Ave.		
		ADDRESS:	VMU
in conformation enhance	eceding-mentioned location has been survermance with standard City practice. As a sment(s):  OSED: Upgrade fifteen (15) existing street	result, we pro	pose the following  / LED, and five (5) to 108W LED.
Install t	hree (3) additional 74W LED street lights	s onto existing	utility poles.


Yours truly,


Approved by:

John T. Boyle, Jr.

Assistant General Manager Vineland Municipal Utilities

Attachments: DWG.#VMEU-2853






SCALE: NTS


DATE: 10/4/2017

CHECKED:

DRAWING # VMEU-2851








SHEET 3 OF 3

PROPOSED STREET LIGHT REVISION BUTLER AVE. BETWEEN EAST BLVD. AND LINCOLN AVE.

DRAWN: EHS	VAULT # F-3-C
DATE: 10/4/2017	DRAWING # VMEU-2851
SCALE: NTS	CHECKED:



SHEET 1 OF 4

KEY


EXISTING SL REMAIN AS IS


INSTALL/REPLACE W/ (8) 74W LED

INSTALL/REPLACE W/ (2) 108W LED

PROPOSED STREET LIGHT REVISION AREA OF EAST BLVD BETWEEN WEYMOUTH ROAD AND WHEAT ROAD

DRAWN: EHS	VAULT # F-3-C
DATE: 10/24/2017	DRAWING # VMEU-2852
SCALE: NTS	CHECKED: A






SHEET 2 OF 4

EXISTING SL REMAIN AS IS

INSTALL/REPLACE W/ (8) 74W LED

PROPOSED STREET LIGHT REVISION AREA OF WEST BLVD BETWEEN CHESTNUT AVENUE AND GRANT AVENUE

	·
DRAWN: EHS	VAULT # F-3-C
DATE: 10/24/2017	DRAWING # VMEU-2852
SCALE: NTS	CHECKED: 19 13



KEY


EXISTING SL REMAIN AS IS

INSTALL/REPLACE W/ (8) 74W LED

INSTALL/REPLACE W/ (1) 108W LED

PROPOSED STREET LIGHT REVISION AREA OF WEST BLVD BETWEEN CHESTNUT AVENUE AND GRANT AVENUE

DRAWN: EHS	VAULT # F-3-C
DATE: 10/24/2017	DRAWING # VMEU-2852
SCALE: NTS	CHECKED:



SHEET 4 OF 4


KEY


EXISTING SL REMAIN AS IS


INSTALL/REPLACE W/ (5) 74W LED

PROPOSED STREET LIGHT REVISION AREA OF WEST BLVD BETWEEN CHESTNUT AVENUE AND GRANT AVENUE

DRAWN: EHS	VAULT # F-3-C
DATE: 10/24/2017	DRAWING # VMEU-2852
SCALE: NTS	CHECKED: AT 13







PROPOSED STREET LIGHT REVISION


HANCE BRIDGE RD. BETWEEN PANTHER RD AND SHERMAN AVE.


VINELAND MUNICIPAL ELECTRIC UTILITY


VINELAND, NEW JERSEY

DRAWN: FHS VAULT # F-3-C

DRAWN: EHS	VAULT # F-3-C
DATE: 11/8/2017	DRAWING # VMEU-2853
SCALE: NTS	CHECKED:







PROPOSED STREET LIGHT REVISION


HANCE BRIDGE RD. BETWEEN PANTHER RD AND SHERMAN AVE.

VINELAND MUNICIPAL ELECTRIC UTILITY

VINELAND, NEW JERSEY

DRAWN: EHS	VAULT # F-3-C
DATE: 11/8/2017	DRAWING # VMEU-2853
SCALE: NTS	CHECKED: A





SHEET 5 OF 5

EXISTING SL REMAIN AS IS

INSTALL/REPLACE W/ (2) 74 W LED

PROPOSED STREET LIGHT REVISION HANCE BRIDGE RD. BETWEEN PANTHER RD AND SHERMAN AVE.

DRAWN: EHS	VAULT # F-3-C
DATE: 11/8/2017	DRAWING # VMEU-2853
SCALE: NTS	CHECKED: